



*2025 Electric Integrated Resource Plan*  
**Technical Advisory Committee Meeting Technical Modeling Workshop**  
**Agenda**  
**Tuesday, June 25, 2024**  
**Virtual Meeting – 9:00 am to 12:00 pm PTZ**

**Topic**

PRiSM Model Tour

New Resource Cost Model

ARAM Model Tour

**Staff**

James Gall

Michael Brutocao

Mike Hermanson

---

**Microsoft Teams meeting**

**Join on your computer, mobile app or room device**

[Click here to join the meeting](#)

Meeting ID: 236 856 615 449

Passcode: BLZnbS

[Download Teams](#) | [Join on the web](#)

**Or call in (audio only)**

[+1 509-931-1514,,527481263#](#) United States, Spokane

Phone Conference ID: 527 481 263#

[Find a local number](#) | [Reset PIN](#)

[Learn More](#) | [Meeting options](#)

---



# PRiSM Model Overview

James Gall, Manager of Resource Planning  
2025 Electric IRP, Technical Modeling Workshop  
June 25, 2024

# What is PRiSM?

- Preferred Resource Strategy Model
- Mixed Integer Program (MIP) used to select new resources to meet resource needs of our customers



The user interface



The solver interface



The solver

## What is new in PRiSM for this IRP?

- Added simplified natural gas LDC system to objective function
  - Model has option to electrify gas customers
  - Impacts to gas/electric system cost and loads are included
- Changed Demand Response options to be valued as a reduction to load rather than a resource
- Includes minimum flexible resource constraint from VER study
- Add new “indicators” – job growth and resource diversity metrics

# Objective Function

Minimize: (WA “Societal” NPV<sub>2026-45</sub>) + (ID NPV<sub>2026-45</sub>) + (NG LDC NPV<sub>2026-45</sub>)

Where:

WA NPV<sub>2026-45</sub> = Market Value of Load + Existing & Future Resource Cost/Operating Margin + Social Cost of Carbon + EE TRC + NEI

ID NPV<sub>2026-45</sub> = Market Value of Load + Existing & Future Resource Cost/Operating Margin + EE UTC

NG LDC NPV<sub>2026-45</sub> = Market Value of Load + Existing & Future Resource Cost/Operating Margin

Subject to:

Generation/Gas Supply Availability & Timing

Energy Efficiency Potential

Demand Response Potential

Monthly Peak Requirements

Monthly Energy Requirements

Monthly Clean Energy Targets

Optimization Tolerance: 0.00001 or 1,500 seconds (Note: certain studies longer solution times allowed)

## Optimized Cost vs. Actual Costs

- Objective function includes social costs that are not part of utility revenue requirement.
- This is used for resource optimization only.
- Social costs may include:
  - Energy Efficiency
    - TRC
    - Non-energy impacts
    - Power Act 10% adder
    - T&D Savings
  - Social Cost of Carbon
- Actual costs illustrate expected cost ratepayers will pay.
- Estimate annual revenue requirements.
- Estimate average rates.

## Aurora Integration

- Aurora's price forecast and resource dispatch are inputs into PRiSM.
- Each **supply resource's** operations is included by iteration.
  - Includes MWh, GHG, Revenue, Fuel Cost, VOM costs.
- **Avista load and existing contracts** are also entered in totals.
- **Energy efficiency** load shapes are marked to market and used for the energy value of these programs.
- **Demand response** options are not modeled in Aurora, but use hourly price results for a market value.

# Energy Efficiency

## Washington

- AEG provides EE potential by year and program
  - Monthly peak savings
  - Monthly energy savings
- Electrical savings are grossed up for T&D losses
- Benefit of T&D Capital Avoidance (\$25.38 per kW-yr)
- Total Resource Cost (TRC) test
- Add value for non-energy impacts by measure
- Power Act 10% adder for energy and capacity value
- Social Cost of Carbon using regional incremental emission rates per MWh
- Included in L&R constraints to avoid new supply resource options

## Idaho

- AEG provides EE potential by year and program
  - Monthly peak savings
  - Monthly energy savings
- Electrical savings are grossed up for T&D losses
- Benefit of T&D Capital Avoidance (\$25.38 per kW-yr)
- Utility Cost Test (UCT) for cost effectiveness
- Included in L&R constraints to avoid new supply resource options



# Demand Response

- Programs available in each state determined by AEG.
- AEG estimated capital amortized over 5 years and a levelized cost is created by combining the O&M costs.
- Projects must ramp in over time.
- Energy arbitrage and savings will be included using hourly optimization model.
  - 10% preference adder included for Washington.
- QCC is 100% for 6 hours of reduction.
  - QCC is reduced by 20% by 2045
- Planning margin is added to QCC value to evaluate resource as a load reduction rather a resource.

## Supply-Side Options

- Uses levelized fixed and variable costs for potentially owned resources (i.e., natural gas, storage).
- Uses PPA \$/MWh or \$/kW-yr costs for resources.
- All generation costs are available on the IRP website.
- Resources must be added in increments of probable size of actual acquisition- not any value- this assumption can increase cost or change resource strategy.
- Resources requiring a “pipeline” have surrogate pipe/storage costs included.

# Transmission

- Resources have either a capital investment or a wheeling charge.
- Locations with transmission constraints with large buildouts have a lower cost transmission charge until the constraint is triggered creating a higher transmission charge.
  - For example: For wind resources, the first 500 MW can be added at \$24/kW then must pay \$258 million for next incremental wind addition.

# Equity Provisions For Washington

- Non-Energy Impacts are included in the optimization
  - Energy efficiency, emissions costs (direct/indirect), safety, induced economic operations
  - Induced economic growth from construction is not included except for a “cost” on out of state resources
  - Maximum Benefit Scenario will have all costs on local resources (27% of CAPEX)
- Named Community Fund Constraints
  - \$2 million per year must be spent on Low Income Energy Efficiency above cost effective selections
  - \$400,000 minimum DER solar/storage investment above cost effective values
- Customer Benefits Indicators are an output of the model



# Resource Adequacy Modeling

ARAM – Avista Resource Adequacy Model


Mike Hermanson, Senior Power Supply Analyst  
Electric IRP, TAC Technical Modeling Workshop  
June 25, 2024

# Overview

- Purpose of the Avista Resource Adequacy Model (ARAM) is to use Monte Carlo analysis techniques to test the ability of a set of resource's ability to meet load and reserve requirements.
- The model is run at an hourly time step. At each time step generators are called upon to meet load and reserve requirements, subject to unique constraints of each generator type, e.g. how much generation is available for a specific water year for a specific month or how much generation is available during a hot summer afternoon from a combined cycle CT.
- There is a range of input data that is selected at random:
  - Water year
  - Load year
  - VER production
  - Forced outages

# Modeling Framework

- Excel based model with VBA code and linear optimization Excel Add-in What's Best!







# Modeling Framework - Thermal

Thermal output is temperature dependent, therefore the capacity available is dependent on the temperature year selected

	Coyote Springs 2	Lancaster	Rathdrum 1	Rathdrum 2	Northeast A	Northeast B	Kettle Falls CT	Boulder Park 1	Boulder Park 2	Boulder Park 3	Boulder Park 4	Boulder Park 5
15	298	258	86	86	0	0	0	4.4	4.4	4.4	4.4	4.4
16	297	257	86	86	0	0	0	4.4	4.4	4.4	4.4	4.4
17	298	257	86	86	0	0	0	4.4	4.4	4.4	4.4	4.4
18	298	257	85	85	0	0	0	4.4	4.4	4.4	4.4	4.4
19	298	257	85	85	0	0	0	4.4	4.4	4.4	4.4	4.4
20	298	256	85	85	0	0	0	4.4	4.4	4.4	4.4	4.4
21	298	256	84	84	0	0	0	4.4	4.4	4.4	4.4	4.4
22	298	256	84	84	0	0	0	4.4	4.4	4.4	4.4	4.4
23	297	255	84	84	0	0	0	4.4	4.4	4.4	4.4	4.4
24	297	255	84	84	0	0	0	4.4	4.4	4.4	4.4	4.4
25	297	255	83	83	0	0	0	4.4	4.4	4.4	4.4	4.4
26	297	254	83	83	0	0	0	4.4	4.4	4.4	4.4	4.4
27	296	254	83	83	0	0	0	4.4	4.4	4.4	4.4	4.4
28	296	253	83	83	0	0	0	4.4	4.4	4.4	4.4	4.4
29	296	253	82	82	0	0	0	4.4	4.4	4.4	4.4	4.4
30	296	253	82	82	0	0	0	4.4	4.4	4.4	4.4	4.4
31	295	252	82	82	0	0	0	4.4	4.4	4.4	4.4	4.4
32	295	252	81	81	0	0	0	4.4	4.4	4.4	4.4	4.4
33	294	251	81	81	0	0	0	4.4	4.4	4.4	4.4	4.4
34	294	251	81	81	0	0	0	4.4	4.4	4.4	4.4	4.4

A regression model produces a market price and thermals are dispatched to that price

	1	2	3	4	5	6	7	8	9	10	11	12
				11,072.50	44.29							
Date	Hour	Hour Type	Market Heat Rate	Market Price	Coyote Springs 2	Coyote Springs 2 Burner	Lancaster	Lancaster Burner	Rathdrum 1	Rathdrum 2	Northeast A	Northeast B
1/1/2030	1	0	12,734	50.94	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	2	0	12,488	49.95	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	3	0	12,451	49.81	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	4	0	12,510	50.04	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	5	0	12,808	51.23	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	6	0	13,150	52.60	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	7	0	13,702	54.81	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	8	0	14,220	56.88	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	9	0	14,456	57.82	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	10	0	14,644	58.58	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	11	0	14,854	59.42	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	12	0	14,814	59.26	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	13	0	14,706	58.82	32.3	34.1	30.1	34.7	46.9	46.9	57.9	
1/1/2030	14	0	14,627	58.51	32.3	34.1	30.1	34.7	46.9	46.9	57.9	

# Modeling Framework - Wind

VER production is based on each projects capacity and then specific hourly values are correlated to temperature and autocorrelated hour to hour.

					Capacity	105.3	100	140	0						6.6%	23.3%	11.2%		
					6.19						9.00						7.52	6.99	
Type	Month	Date	Hour Type	Hour	Temp	Palouse	Montana	Rattle Snake	Project 1	Project 2	Total	Palouse Wind Speed	Palouse Adjustm ent	Montana Wind Speed	Montana Adjustm ent	RattleSnake Wind Speed	RattleSnake Adjustm ent	Project 1 Wind Speed	Project 1 Adjustm ent
&0	1	1/1/2030	0	1	2.2	0%	23%	87%	0%	14%	145.1	1.02	(0.17)	7.15	(0.08)	14.85	(0.12)	2.60	0.22
&0	1	1/1/2030	0	2	0	0%	23%	87%	0%	12%	145.1	1.05	0.04	7.04	(0.10)	15.08	0.23	2.62	0.02
&0	1	1/1/2030	0	3	-1.8	0%	27%	87%	0%	12%	148.6	1.11	0.06	7.36	0.32	15.37	0.29	2.36	(0.26)
&0	1	1/1/2030	0	4	-3.1	0%	27%	87%	0%	12%	148.6	1.21	0.10	7.19	(0.17)	15.31	(0.06)	2.50	0.14
&0	1	1/1/2030	0	5	-3.9	0%	27%	87%	0%	0%	148.6	1.26	0.05	7.22	0.02	15.23	(0.07)	2.56	0.06
&0	1	1/1/2030	0	6	-4	0%	23%	87%	0%	0%	145.1	1.13	(0.13)	7.19	(0.03)	15.19	(0.04)	2.56	(0.00)
&1	1	1/1/2030	1	7	-3.4	0%	23%	87%	0%	0%	145.1	1.21	0.08	6.96	(0.22)	15.14	(0.05)	2.58	0.02
&1	1	1/1/2030	1	8	-2.3	0%	20%	87%	0%	0%	142.1	1.24	0.03	6.81	(0.16)	15.04	(0.10)	2.51	(0.07)
&1	1	1/1/2030	1	9	-0.6	0%	20%	87%	0%	34%	142.1	1.26	0.02	6.82	0.01	14.96	(0.08)	2.52	0.01
&1	1	1/1/2030	1	10	1.4	0%	20%	87%	0%	38%	142.1	1.28	0.02	6.76	(0.06)	14.72	(0.24)	2.34	(0.18)
&1	1	1/1/2030	1	11	3.7	0%	23%	87%	0%	0%	145.1	1.41	0.13	7.10	0.33	14.63	(0.09)	2.28	(0.06)
&1	1	1/1/2030	1	12	5.9	0%	58%	87%	100%	12%	180.3	1.52	0.11	9.46	(0.23)	14.93	0.28	14.40	0.06
&1	1	1/1/2030	1	13	8.1	0%	58%	87%	100%	43%	180.3	1.36	(0.16)	9.45	(0.01)	14.91	(0.03)	14.51	0.11
&1	1	1/1/2030	1	14	9.8	0%	100%	87%	0%	4%	222.1	1.55	0.19	15.35	(0.07)	18.15	(0.15)	1.67	0.08
&1	1	1/1/2030	1	15	11.1	0%	100%	87%	0%	6%	222.1	1.43	(0.12)	15.69	0.34	18.37	0.22	1.72	0.05
&1	1	1/1/2030	1	16	11.9	0%	100%	87%	0%	6%	222.1	1.46	0.03	15.52	(0.17)	18.48	0.11	1.46	(0.26)
&1	1	1/1/2030	1	17	12	0%	100%	87%	0%	4%	222.1	1.53	0.07	15.56	0.04	18.70	0.23	1.52	0.06
&1	1	1/1/2030	1	18	11.4	0%	100%	87%	0%	6%	222.1	1.52	(0.01)	15.57	0.01	18.96	0.25	1.51	(0.01)
&1	1	1/1/2030	1	19	10.2	0%	100%	87%	0%	4%	222.1	1.39	(0.13)	15.50	(0.07)	18.99	0.04	1.58	0.07
&1	1	1/1/2030	1	20	8.5	0%	100%	87%	0%	6%	222.1	1.29	(0.10)	15.53	0.03	19.17	0.18	1.69	0.11
&1	1	1/1/2030	1	21	6.5	0%	100%	87%	0%	6%	222.1	1.25	(0.04)	15.40	(0.13)	18.96	(0.21)	1.67	(0.02)
&1	1	1/1/2030	1	22	4.2	0%	100%	87%	0%	4%	222.1	1.27	0.02	15.32	(0.08)	19.04	0.08	1.74	0.08
&0	1	1/1/2030	0	23	2	0%	100%	87%	0%	6%	222.1	1.54	0.26	15.21	(0.11)	19.05	0.01	1.84	0.10

# Modeling Framework - Load

Hourly load values are developed in a separate regression model that produces hourly loads based on temperature, day of week, holiday vs non-holiday, etc.

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	
Date	Hour	1947	1948	1949	1950	1951	1952	1953	1954	1955	1956	1957	1958	1959	1960	1961	1962	1963	1964	1965	
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Date	Hour	1947	1948	1949	1950	1951	1952	1953	1954	1955	1956	1957	1958	1959	1960	1961	1962	1963	1964	1965	
1/1/2030	1	-1198	-961	-1089	-997	-1097	-1351	-966	-922	-1011	-1038	-1025	-1002	-1037	-1214	-1067	-943	-912	-975	-1080	
1/1/2030	2	-1225	-940	-1097	-986	-1043	-1381	-951	-903	-977	-1029	-997	-1006	-1014	-1233	-1052	-924	-885	-939	-1066	
1/1/2030	3	-1261	-934	-1119	-987	-1007	-1418	-951	-899	-959	-1032	-983	-1022	-1007	-1263	-1051	-918	-871	-920	-1065	
1/1/2030	4	-1298	-945	-1149	-998	-1017	-1444	-961	-910	-969	-1049	-991	-1037	-1027	-1297	-1058	-923	-880	-932	-1079	
1/1/2030	5	-1345	-977	-1194	-1030	-1048	-1486	-992	-942	-1000	-1085	-1022	-1071	-1065	-1343	-1088	-952	-910	-965	-1113	
1/1/2030	6	-1417	-1046	-1265	-1098	-1117	-1557	-1060	-1011	-1068	-1154	-1089	-1140	-1135	-1414	-1155	-1019	-978	-1034	-1181	
1/1/2030	7	-1494	-1131	-1344	-1183	-1201	-1636	-1145	-1096	-1153	-1237	-1175	-1223	-1217	-1492	-1241	-1105	-1063	-1118	-1265	
1/1/2030	8	-1537	-1192	-1392	-1244	-1264	-1687	-1207	-1157	-1216	-1295	-1239	-1282	-1273	-1537	-1306	-1171	-1127	-1179	-1325	
1/1/2030	9	-1523	-1205	-1384	-1257	-1278	-1682	-1221	-1170	-1230	-1301	-1254	-1292	-1277	-1526	-1322	-1190	-1142	-1192	-1335	
1/1/2030	10	-1495	-1209	-1363	-1261	-1283	-1665	-1226	-1174	-1235	-1298	-1261	-1291	-1269	-1500	-1331	-1201	-1150	-1194	-1335	
1/1/2030	11	-1458	-1206	-1335	-1258	-1282	-1639	-1225	-1172	-1234	-1287	-1262	-1283	-1255	-1467	-1334	-1206	-1151	-1190	-1329	
1/1/2030	12	-1412	-1194	-1298	-1244	-1272	-1603	-1214	-1159	-1224	-1267	-1253	-1266	-1231	-1425	-1326	-1202	-1142	-1177	-1312	
1/1/2030	13	-1373	-1183	-1265	-1233	-1263	-1572	-1204	-1149	-1215	-1250	-1245	-1250	-1210	-1388	-1320	-1198	-1135	-1165	-1298	
1/1/2030	14	-1334	-1168	-1232	-1218	-1249	-1540	-1190	-1134	-1201	-1229	-1233	-1231	-1187	-1351	-1309	-1190	-1123	-1149	-1280	
1/1/2030	15	-1297	-1148	-1201	-1198	-1231	-1507	-1172	-1115	-1183	-1205	-1216	-1209	-1162	-1316	-1293	-1176	-1105	-1129	-1258	
1/1/2030	16	-1295	-1156	-1201	-1206	-1239	-1508	-1180	-1122	-1192	-1210	-1224	-1215	-1166	-1315	-1302	-1187	-1114	-1137	-1265	
1/1/2030	17	-1340	-1203	-1246	-1253	-1286	-1553	-1228	-1170	-1239	-1256	-1272	-1262	-1212	-1360	-1351	-1235	-1162	-1184	-1312	
1/1/2030	18	-1388	-1247	-1292	-1297	-1330	-1602	-1272	-1213	-1283	-1301	-1316	-1306	-1257	-1408	-1394	-1278	-1205	-1227	-1357	
1/1/2030	19	-1389	-1235	-1289	-1286	-1318	-1600	-1260	-1202	-1271	-1293	-1303	-1297	-1249	-1408	-1380	-1263	-1192	-1216	-1347	
1/1/2030	20	-1377	-1204	-1271	-1254	-1285	-1583	-1227	-1170	-1237	-1265	-1269	-1268	-1223	-1393	-1346	-1226	-1158	-1184	-1317	
1/1/2030	21	-1368	-1169	-1256	-1221	-1249	-1569	-1191	-1135	-1201	-1237	-1232	-1238	-1197	-1383	-1307	-1184	-1121	-1151	-1286	
1/1/2030	22	-1347	-1117	-1226	-1169	-1195	-1538	-1137	-1082	-1147	-1192	-1176	-1190	-1155	-1358	-1250	-1124	-1064	-1099	-1238	
1/1/2030	23	-1327	-1061	-1197	-1113	-1138	-1506	-1081	-1027	-1090	-1145	-1116	-1140	-1111	-1334	-1188	-1060	-1005	-1045	-1186	

# Reserves

- Spin and non-spin reserves are based on generation, load, regulation, and flex ramp for VERs. Reserve requirements are calculated on an hourly basis and optimization is utilized to determine how reserves are met.

Reserves				Flex Ramp Up Regression Coefficients																				
				Intercept		97.28334		Load		0.0080														
				Total Solar Production		0.464152		Total Wind Production		0.103225														
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
				Reserve Calculations																				
				Assumed Values																				
				345.3	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	Non-Spin	No
Date	Hour	Hour Type	Load Regulation	Flex Ramp UP	Rathdrum 1	Rathdrum 2	Northeast A	Northeast B	New Resource Peaker	New Resource Peaker	Cabinet 1	Cabinet 2	Cabinet 3	Cabinet 4	Noxon 1	Noxon 2	Noxon 3	Noxon 4	Noxon 5	Long Lake 1	Long Lake 2	Long Lake 3	Long Lake 4	Lit
1/1/2030	1	0	10	124.2	0.0	0.0	0.0	0.0	0.0	0.0	56.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	2	0	10	124.2	0.0	0.0	0.0	0.0	0.0	0.0	55.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	3	0	10	124.7	0.0	0.0	0.0	0.0	0.0	0.0	56.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	4	0	10	124.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	57.2	0.0	0.0	0.0	0.0	0.0
1/1/2030	5	0	10	125.2	0.0	0.0	0.0	0.0	0.0	0.0	58.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	6	0	10	125.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	61.7	0.0	0.0	0.0	0.0
1/1/2030	7	0	10	126.0	0.0	0.0	0.0	0.0	0.0	0.0	64.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	8	0	10	126.1	0.0	0.0	0.0	0.0	0.0	0.0	66.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	9	0	10	127.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	66.1	0.0	0.0	0.0	0.0
1/1/2030	10	0	10	126.9	0.0	0.0	0.0	0.0	0.0	0.0	65.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	11	0	10	126.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	64.8	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	12	0	10	130.0	0.0	0.0	0.0	0.0	0.0	0.0	64.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	13	0	10	129.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	63.7	0.0	0.0	0.0	0.0
1/1/2030	14	0	10	133.7	0.0	0.0	0.0	0.0	0.0	0.0	64.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	15	0	10	134.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	62.9	0.0	0.0	0.0	0.0
1/1/2030	16	0	10	134.0	0.0	0.0	0.0	0.0	0.0	0.0	62.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	17	0	10	133.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	64.5	0.0	0.0	0.0	0.0	0.0	0.0
1/1/2030	18	0	10	133.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	66.2	0.0	0.0	0.0	0.0	0.0
1/1/2030	19	0	10	133.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	66.1	0.0	0.0	0.0	0.0	0.0
1/1/2030	20	0	10	133.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	65.6	0.0	0.0	0.0	0.0	0.0

# Operations

- Operations sheet brings all of the pieces together to determine if load and reserves have been met.
- Includes market purchases and sales, demand response, contracts,

	3%											
ew	Washington	Industrial	TOU	VPP	On-Peak	Off-Peak	On-Peak	Off-Peak	Reserve	Unreserved	Net	
age	Industrial	Load Reduction			Market Purchase	Market Purchase	Market Sale	Market Sale	Call	Energy	Position	
	-82.8	0	0	0	0	0	0	120	0	0.0	0	
	-82.8	0	0	0	0	0	0	103	0	0.0	0	
	-82.8	0	0	0	0	0	0	98	0	0.0	0	
	-82.8	0	0	0	0	0	0	77	0	0.0	0	
	-82.8	0	0	0	0	0	0	37	0	0.0	0	
	-82.8	0	0	0	0	10	0	0	0	0.0	0	
	-82.8	0	0	0	0	108	0	0	0	0.0	0	
	-82.8	0	0	0	0	165	0	0	0	0.0	0	
	-82.8	0	0	0	0	162	0	0	0	0.0	0	
	-82.8	0	0	0	0	151	0	0	0	0.0	0	
	-82.8	0	0	0	0	130	0	0	0	0.0	0	
	-82.8	0	0	0	0	62	0	0	0	0.0	0	
	-82.8	0	0	0	0	38	0	0	0	0.0	0	
	-82.8	0	0	0	0	0	0	34	0	0.0	0	
	-82.8	0	0	0	0	0	0	61	0	0.0	0	
	-82.8	0	0	0	0	0	0	59	0	0.0	0	
	-82.8	0	0	0	0	0	0	12	0	0.0	0	
	-82.8	0	0	0	0	0	0	34	0	0.0	0	
	-82.8	0	0	0	0	35	0	0	0	0.0	0	
	-82.8	0	0	0	0	31	0	0	0	0.0	0	
	-82.8	0	0	0	0	7	0	0	0	0.0	0	
	-82.8	0	0	0	0	0	0	14	0	0.0	0	
	-82.8	0	0	0	0	0	0	52	0	0.0	0	
	-82.8	0	0	0	0	0	0	109	0	0.0	0	

BO	BP	BQ	BR	BS	BT	BU	BV	BW	BX	BY	BZ	CA	CB	CC
67	68	69	70	71	72	73	74	75	76	77	78	79	80	
							Market Cap							
							All Hours	1000	1000	5	Low			
							Constained Hours	330	330	83	High			
													Demand Response	
Total	Balance	On-Peak	Off-Peak	On-Peak	Off-Peak	On-Peak	Off-Peak	Regional	Industrial	Public	Industrial	VPP		
		Market	Market	Market	Market	Market	Market	Power	Hour	Hour	Constraint			
		Sale	Sale	Purchase	Purchase	Purchase	Purchase	Constraint						
		Constraint	Constraint	Constraint	Constraint	Constraint	Constraint							
								On-Peak	Off-Peak					
								Max	Max					
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		
0	=	<=	<=	<=	<=	<=	<=	0	330	1	<=	<=		

# Analysis Approach

- Utilizes Monte Carlo Methods
  - Run 1,000 simulations of 1 year at an hourly time step.
  - Determine how many time during the simulation there was a loss of load or reserve requirements could not be met.
  - Calculate Metrics:
    - **LOLP** – *Loss of Load Probability*: Calculated by counting the number of iterations where there is unserved load or unmet reserves and dividing by the total number of iterations.
    - **LOLE** – *Loss of Load Expectation*: Calculated by counting the days where there is unserved load or unmet reserves and dividing by the total number of iterations.
    - **LOLEV** – *Loss of Load Expected Events*: Calculated by counting the number of consecutive blocks of unserved load or unmet reserves and dividing by the number of iterations.
    - **LOLH** – *Loss of Load Hours*: Calculated by summing the number of hours with unserved load or unmet reserves and dividing by the total number of iterations.
    - **EUE** – *Expected Unserved Energy*: Calculated by summing all of the unserved MWhs over the study period and dividing by the number of iterations. Two versions are presented one with unmet reserves and one without.