



*2025 Natural Gas Integrated Resource Plan*  
**Technical Advisory Committee Meeting No. 4 Agenda**  
Wednesday, June 5, 2024  
Virtual Meeting

<b>Topic</b>	<b>Time (PTZ)</b>	<b>Staff</b>
Feedback from prior TAC	9:00	Tom Pardee
Distribution System Modeling	9:10	Terrence Browne
OPUC Recommendation on NPA	10:10	OPUC Staff
Targeted Energy Efficiency	10:35	ETO
Weather Futures and Peak Planning	11:00	Tom Pardee
TAC feedback	11:50	All

## Microsoft Teams meeting

**Join on your computer, mobile app or room device**

[Click here to join the meeting](#)

Meeting ID: 285 938 629 442

Passcode: 8TysAy

[Download Teams](#) | [Join on the web](#)

**Or call in (audio only)**

[+1 509-931-1514,,325846108#](#) United States, Spokane

Phone Conference ID: 325 846 108#

[Find a local number](#) | [Reset PIN](#)

[Learn More](#) | [Meeting options](#)



# Distribution System Planning


Terrence Browne PE, Principal Gas Planning Engineer

Natural Gas Technical Advisory Committee

June 5, 2024

# Mission

- Using technology to plan and design a safe, reliable, and economical distribution system




# Service Territory and Customer Overview

- Serves electric and natural gas customers in eastern Washington and northern Idaho, and natural gas customers in southern and eastern Oregon

– Population of service area 1.7 million


▶ 414,000 electric customers

▶ 378,000 natural gas customers







# 5 Variables for Any Given Pipe



# Scope of Gas Distribution Planning




# Scope of Gas Distrib. Planning cont.








# SynerGi (SynerGEE, Stoner) Load Study

- Simulate distribution behavior
- Identify low pressure areas
- Test reinforcements against future growth/expansion
- Measure reliability



# Creating a Pipeline Model

- Elements
  - Pipes, regulators, valves
  - Attributes: Length, internal diameter, roughness
- Nodes
  - Sources, usage points, pipe ends
  - Attributes: Flow, pressure



# Estimating Customer Usage

- Gathering Data
  - Days of service
  - Degree Days
  - Usage
  - Name, Address, Revenue Class, Rate Schedule...




# Estimating Customer Usage cont.

- Degree Days
  - Heating (HDD)
  - Cooling (CDD)
- Temperature - Usage Relationship
  - Load vs. HDD's
  - Base Load (constant)
  - Heat Load (variable)
  - High correlation with residential

Avg. Daily Temperature ('Fahrenheit)	Heating Degree Days (HDD)	Cooling Degree Days (CDD)
85		20
80		15
75		10
70		5
65	0	0
60	5	
55	10	
50	15	
45	20	
40	25	
35	30	
30	35	
25	40	
20	45	
15	50	
10	55	
5	60	
4	61	
0	65	
-5	70	
-10	75	
-15	80	

# Load vs. Temperature



# Monitoring Our System


- Electronic Pressure Recorders
  - Daily Feedback
  - Real time if necessary
- Validates our Load Studies



# Validating Model


- Simulate recorded condition
- Electronic Pressure Recorders
  - Do calculated results match field data?
- Gate Station Telemetry
  - Do calculated results match source data?
- Possible Errors
  - Missing pipe
  - Source pressure changed
  - Industrial loads

# Post Falls State Line





# Hayden Lake




01-27-2014 8:39:14.465 AM

14.00 days

02-10-2014 8:39:14.465 AM

- P1 Interval High
- P1 Interval Average
- ◆ P1 Interval Low

# South Hayden Lake



# Planning Criteria – 2023

- Reliability during design HDD
  - Spokane **76 HDD** (*avg. daily temp. -11' F*)
  - Medford **49 HDD** (*avg. daily temp. 16' F*)
  - Klamath Falls **72 HDD** (*avg. daily temp. -7' F*)
  - La Grande **72 HDD** (*avg. daily temp. -7' F*)
  - Roseburg **46 HDD** (*avg. daily temp. 19' F*)
- Maintain minimum of 15 psig in system at all times
  - 5 psig in lower MAOP areas
  - 3 psig in Medford 6 psig systems

# Fixes and Reinforcements

- Identify Low Pressure Areas
  - Number of feeds
  - Proximity to source
- Looking for Most Economical Solution
  - Length (minimize)
  - Construction obstacles (minimize)
- Lead Times:
  - Design and engineering; 12 months
  - Real estate, permits, and environmental; 6-24 months
  - Material ordering and delivery; 3-6 months


# Non-Pipe Alternatives (NPAs)

- System Pressure Upgrades
- Conservation
- Electrification




# NPA: System Pressure Uprates

- Objective
  - Raise source pressure to increase capacity
- Process
  - Deep dive into records
  - Series of leak surveys
- Challenges
  - Remaining opportunities?
- Lead time
  - 6-12 months



# NPA: Conservation

- Objective
  - Reduce customer demand on distribution
- Process
  - Targeted Load Management (TLM) programs
    - Identify opportunities and energy efficiency potential
    - Implement energy efficiency measures
- Challenges
  - Minimal benefits realized at distribution locations
  - More effective on supply side
- Lead time
  - 3-5 years



# NPA: Conservation

- Results of Energy Trust TLM analysis (Oct 5<sup>th</sup> 2023)

## Avista TLM: Total Potential and Program Activity

Area	Utility Target Goal	Total Efficiency Resource	Historic Annual Average
Medford	691	479	11
Sutherlin	121	158	2

*peak hour therms*

*three-year total efficiency resource; cost-effective achievable potential*

- Resource assessment modelling results demonstrate there is not enough peak reduction to meet AVI load reduction targets.
  - The Medford AVI target is **144%** of resource potential.
  - The Sutherlin AVI target is **77%** of resource potential.
- Program history shows the targets are 60x greater than a typical year of program activity.



# NPA: Conservation

- Results of Energy Trust TLM analysis (Oct 5<sup>th</sup> 2023)

## Avista TLM: Forecast Using NWN Pilot Results

Area	Utility Target Goal	Pilot Total Resource Results	Pilot Historical Results
Medford	691	66	63
Sutherlin	121	18	12

*peak hour therms*


*assumes three-year TLM project*

*29 years needed to achieve targets at NWN pilot rate*

- NWN Pilot achieved 4% of resource potential in two years of enhanced incentives.
  - Generalizing to a three-year project this equates to roughly 12% of Avista's targets.
- NWN Pilot nearly doubled historical acquisition.
  - This would result in about 9% of Avista's targets in a three-year period.

# NPA: Electrification

- Objective
  - Eliminate customer demand on distribution
- Process
  - Identify customers in deficient areas
  - Transition to electric appliances/load
- Challenges
  - Transition may be expensive (cost of appliances)
  - Limited capacity and infrastructure of electric utility
    - Who pays for upgrade
- Lead time
  - 1-?? years



# Areas Currently Monitoring for Low Pressure and Proposed Solutions\*

- Medford 6 psig system, OR
- Airway Heights, WA
- South Hill Spokane, WA
- Schweitzer Resort, ID
- Moscow, ID
- \*Notes:
  - List not comprehensive
  - projects are subject to change and will be reviewed on a regular basis



# City Gate Stations Currently Monitoring and Proposed Solutions\*

- Sutherlin, OR: *rebuild/enhance in 2024+*
- Malin, OR: *observe, rebuild/enhance in 2025+*
- Medford, OR: *work with pipeline to increase capacity*
- Rathdrum – Chase, ID: *rebuild/enhance in 2024+*
- Pullman, WA: *work with pipeline to increase capacity*
- \*Notes:
  - List not comprehensive
  - projects are subject to change and will be reviewed on a regular basis

# Questions and Discussion



## *Mission*

***Using technology to plan and design a safe, reliable, and economical distribution system***



# Avista 2025 Gas IRP TAC 4

STAFF'S PROPOSAL FOR  
NON PIPE ALTERNATIVES

Nick Sayen  
Senior Utility Analyst  
June 5, 2024



# Staff's Proposal

*....Staff expects the Company to update its distribution system planning practices and IRP processes to include:*

- Guidance from Attachment A to Staff's Report in Order No. 23-023;*
- Direction provided by Order No. 23-281;*
- Practices agreed to through Stipulation Item 21 in Order No. 23-384; and*
- Several of the extensions of Stipulation Item 21 suggested by Climate Advocates.*

*Specific elements of Staff's expectation are included in Attachment C. **Staff emphasizes this expectation does not include significant, new concepts.** With the exception of three items (2e., 2f., and 3) all of these practices have already been included in Commission Orders. Staff's expectation **simply assembles these concepts into a more cohesive package.***

# Attachment C

1. Future distribution system planning should identify the rationale for projects as either Safety/General System Reliability, or Customer Growth/Reliability Related to Growth.
  - a. When proposing growth-driven projects in IRPs the utility should be prepared to present project data on: relationship to CPP compliance strategy, modeling and verified measurement, local load forecast, and assessment of alternatives through the NPA framework.

## Attachment C

The Company should update its DSP practices and IRP processes to include:

1. Future distribution system planning should identify the rationale for projects as either Safety/General System Reliability, or Customer Growth/Reliability Related to Growth.
  - a. When proposing growth-driven projects in IRPs the utility should be prepared to present project data on: relationship to CPP compliance strategy, modeling and verified measurement, local load forecast, and assessment of alternatives through the NPA framework.
2. Future distribution system planning should include an NPA framework in Oregon. The framework should include:
  - a. NPA analysis will be performed for supply-side resources (these include but are not limited to all resources upstream of Avista's distribution system and city gates, and supply-side contracts) and for distribution system reinforcements and expansion projects that exceed a threshold of \$1 million for individual projects or groups of geographically related projects (a group of projects that are interdependent or interrelated).
  - b. NPA analysis will include cost benefit analysis that reflects an avoided GHG compliance cost element consistent with a high-cost estimate of future alternative fuels prices. Non-Energy Impacts must be included as part of the NPA analysis.
  - c. NPA analysis will include electrification, targeted energy efficiency, targeted demand response, and other alternative solutions.
  - d. NPA analysis should look forward five years to allow ample time for evaluation and implementation.
  - e. NPA analysis will include an explanation of solutions considered and evaluated including a description of the projected timeline and annual implementation rate for the solutions evaluated, the technical feasibility of the solutions, and the strategy to implement the solutions evaluated.
  - f. NPA analysis should include an explanation of the resulting investment selection (either NPA or a traditional investment) including the costs and ranking of the solutions, and the criteria used to rank or eliminate them.
    - i. If a NPA is not selected and the reason is insufficient implementation time, it should include steps the Company will take to perform NPA analysis to provide sufficient implementation time for future projects.
3. Future IRPs should include the results of distribution system planning, including project data and NPA analysis for any proposed traditional investments, and NPA analysis for any proposed NPA.
4. Future IRPs should include a database containing information about feeders, in service dates of pipes, and lowest recent observed pressures.





# Attachment C

2. Future distribution system planning should include an NPA framework in Oregon. The framework should include:
  - a. NPA analysis will be performed for supply-side resources (these include but are not limited to all resources upstream of Avista's distribution system and city gates, and supply-side contracts) and for distribution system reinforcements and expansion projects that exceed a threshold of \$1 million for individual projects or groups of geographically related projects (a group of projects that are interdependent or interrelated).
  - b. NPA analysis will include cost benefit analysis that reflects an avoided GHG compliance cost element consistent with a high-cost estimate of future alternative fuels prices. Non-Energy Impacts must be included as part of the NPA analysis.
  - c. NPA analysis will include electrification, targeted energy efficiency, targeted demand response, and other alternative solutions.

## Attachment C

- update its DSP practices and IRP processes to include:
- distribution system planning should identify the rationale for projects as either System Reliability, or Customer Growth/Reliability Related to Growth. Proposing growth-driven projects in IRPs the utility should be prepared to project data on: relationship to CPP compliance strategy, modeling and measurement, local load forecast, and assessment of alternatives to the NPA framework.
- distribution system planning should include an NPA framework in Oregon. The framework should include:
- a. NPA analysis will be performed for supply-side resources (these include but are not limited to all resources upstream of Avista's distribution system and city gates, and supply-side contracts) and for distribution system reinforcements and expansion projects that exceed a threshold of \$1 million for individual projects or groups of geographically related projects (a group of projects that are interdependent or interrelated).
  - b. NPA analysis will include cost benefit analysis that reflects an avoided GHG compliance cost element consistent with a high-cost estimate of future alternative fuels prices. Non-Energy Impacts must be included as part of the NPA analysis.
  - c. NPA analysis will include electrification, targeted energy efficiency, targeted demand response, and other alternative solutions.
  - d. NPA analysis should look forward five years to allow ample time for evaluation and implementation.
  - e. NPA analysis will include an explanation of solutions considered and evaluated including a description of the projected timeline and annual implementation rate for the solutions evaluated, the technical feasibility of the solutions, and the strategy to implement the solutions evaluated.
  - f. NPA analysis should include an explanation of the resulting investment selection (either NPA or a traditional investment) including the costs and ranking of the solutions, and the criteria used to rank or eliminate them.
    - i. If a NPA is not selected and the reason is insufficient implementation time, it should include steps the Company will take to perform NPA analysis to provide sufficient implementation time for future projects.
3. Future IRPs should include the results of distribution system planning, including project data and NPA analysis for any proposed traditional investments, and NPA analysis for any proposed NPA.
  4. Future IRPs should include a database containing information about feeders, in service dates of pipes, and lowest recent observed pressures.

# Attachment C

2. Future distribution system planning should include an NPA framework in Oregon. The framework should include:

- d. NPA analysis should look forward five years to allow ample time for evaluation and implementation.
- e. NPA analysis will include an explanation of solutions considered and evaluated including a description of the projected timeline and annual implementation rate for the solutions evaluated, the technical feasibility of the solutions, and the strategy to implement the solutions evaluated.
- f. NPA analysis should include an explanation of the resulting investment selection (either NPA or a traditional investment) including the costs and ranking of the solutions, and the criteria used to rank or eliminate them.
  - i. If a NPA is not selected and the reason is insufficient implementation time, it should include steps the Company will take to perform NPA analysis to provide sufficient implementation time for future projects.

## Attachment C

DSP practices and IRP processes to include:

Planning should identify the rationale for projects as either reliability or Customer Growth/Reliability Related to Growth. Growth-driven projects in IRPs the utility should be prepared to discuss: relationship to CPP compliance strategy, modeling and rent, local load forecast, and assessment of alternatives framework.

Planning should include an NPA framework in Oregon. The

be performed for supply-side resources (these include but are not limited to resources upstream of Avista's distribution system and city side contracts) and for distribution system reinforcements and projects that exceed a threshold of \$1 million for individual projects or financially related projects (a group of projects that are financially related).

Include cost benefit analysis that reflects an avoided GHG emission consistent with a high-cost estimate of future prices. Non-Energy Impacts must be included as part of the NPA

include electrification, targeted energy efficiency, targeted investments, and other alternative solutions.

should look forward five years to allow ample time for evaluation and implementation.

include an explanation of solutions considered and evaluated including a description of the projected timeline and annual implementation rate for the solutions evaluated, the technical feasibility of the solutions, and the strategy to implement the solutions evaluated.

should include an explanation of the resulting investment selection (either NPA or a traditional investment) including the costs and ranking of the solutions, and the criteria used to rank or eliminate them.

If a NPA is not selected and the reason is insufficient implementation time, it should include steps the Company will take to perform NPA analysis to provide sufficient implementation time for future projects.

3. Future IRPs should include the results of distribution system planning, including project data and NPA analysis for any proposed traditional investments, and NPA analysis for any proposed NPA.

4. Future IRPs should include a database containing information about feeders, in service dates of pipes, and lowest recent observed pressures.

# Attachment C

3. Future IRPs should include the results of distribution system planning, including project data and NPA analysis for any proposed traditional investments, and NPA analysis for any proposed NPA.
4. Future IRPs should include a database containing information about feeders, in service dates of pipes, and lowest recent observed pressures.

## Attachment C

The Company should update its DSP practices and IRP processes to include:

1. Future distribution system planning should identify the rationale for projects as either Safety/General System Reliability, or Customer Growth/Reliability Related to Growth.
  - a. When proposing growth-driven projects in IRPs the utility should be prepared to present project data on: relationship to CPP compliance strategy, modeling and verified measurement, local load forecast, and assessment of alternatives through the NPA framework.
2. Future distribution system planning should include an NPA framework in Oregon. The framework should include:
  - a. NPA analysis will be performed for supply-side resources (these include but are not limited to all resources upstream of Avista's distribution system and city gates, and supply-side contracts) and for distribution system reinforcements and expansion projects that exceed a threshold of \$1 million for individual projects or groups of geographically related projects (a group of projects that are interdependent or interrelated).
  - b. NPA analysis will include cost benefit analysis that reflects an avoided GHG compliance cost element consistent with a high-cost estimate of future alternative fuels prices. Non-Energy Impacts must be included as part of the NPA analysis.
  - c. NPA analysis will include electrification, targeted energy efficiency, targeted demand response, and other alternative solutions.
  - d. NPA analysis should look forward five years to allow ample time for evaluation and implementation.
  - e. NPA analysis will include an explanation of solutions considered and evaluated including a description of the projected timeline and annual implementation rate for the solutions evaluated, the technical feasibility of the solutions, and the strategy to implement the solutions evaluated.
  - f. NPA analysis should include an explanation of the resulting investment selection (either NPA or a traditional investment) including the costs and ranking of the solutions, and the criteria used to rank or eliminate them.
    - i. If a NPA is not selected and the reason is insufficient implementation time, it should include steps the Company will take to perform NPA analysis to provide sufficient implementation time for future projects.
3. Future IRPs should include the results of distribution system planning, including project data and NPA analysis for any proposed traditional investments, and NPA analysis for any proposed NPA.
4. Future IRPs should include a database containing information about feeders, in service dates of pipes, and lowest recent observed pressures.



# Thank you



Nick Sayen

Senior Utility Analyst

(503) 510-4355

[nick.sayen@puc.oregon.gov](mailto:nick.sayen@puc.oregon.gov)



# Targeted Load Management Overview

Energy Trust and Avista

June 2024



# Agenda

- What is TLM at Energy Trust?
- TLM Process Phases
- Program Implementation Strategies
- Prior TLM Examples- Medford and Sutherlin

# What is TLM at Energy Trust?

## **A range of planning, program and community services:**

- Market intelligence and characterization
- Resource potential analysis
- Program design and delivery strategies
- Customer and community engagement

## **Objectives:**

- Determine whether targeted energy efficiency can meet local utility system needs
- Deliver benefits to utility and local communities



# Targeted Load Management Process Phases



\*Could include funding beyond current PPC funds



# Program Implementation Strategies

Previous TLM efforts included:

- **Increased incentives:** maximum based on cost effectiveness, and max allowed based on localized avoided costs
- **Increased Trade Ally (TA) engagement:** training, participation agreements, single point of contact support, incentive form assistance
- **Increased Trade Ally Business Development Funds:** to subsidize and support TA sponsored marketing efforts
- **Increased Marketing:** local newspapers, social media, tabling at local events, TLM landing page
- **Increased Customer outreach and engagement:** proactive contact with large commercial and industrial customers

# Avista TLM Analysis: Medford and Sutherlin

# Avista TLM: Load Forecast Composition

<i>Customer Segment</i>	<b>Medford</b>	<b>Sutherlin</b>
<b>Residential</b>	62%	64%
<b>Commercial</b>	37%	25%
<b>Industrial</b>	1%	10%

- The load forecast and premise IDs identified in each TLM area are primarily residential with some commercial and industrial.
  - This load breakdown was used as input to the resource assessment model

# Avista TLM: Total Potential and Program Activity

<i>Area</i>	<b>Utility Target Goal</b>	<b>Total Efficiency Resource</b>	<b>Historic Annual Average</b>
<b>Medford</b>	691	479	11
<b>Sutherlin</b>	121	158	2
<i>peak hour therms</i>			
<i>three-year total efficiency resource; cost-effective achievable potential</i>			


- Resource assessment modelling results demonstrate there is not enough peak reduction to meet AVI load reduction targets.
  - The Medford AVI target is **144%** of resource potential.
  - The Sutherlin AVI target is **77%** of resource potential.
- Program history shows the targets are 60x greater than a typical year of program activity.

# Thank you!

Adam Shick, Planning Manger  
[adam.shick@energytrust.org](mailto:adam.shick@energytrust.org)

Spencer Moersfelder, Director of Planning and Evaluation  
[spencer.moersfelder@energytrust.org](mailto:spencer.moersfelder@energytrust.org)

Willa Perlman, Planning Project Manager  
[willa.perlman@energytrust.org](mailto:willa.perlman@energytrust.org)



# Supplemental Slides

# Resource Assessment Overview

## What is a resource assessment?

- Estimate of energy efficiency resource potential at a range of costs that is achievable over a defined number of years
- Identifies opportunities for energy efficiency measures within a territory based on existing conditions of building stock

## What is it used for?

- The purpose is to help Energy Trust and utilities strategically plan future investments in both demand side and supply side resources
- Provides a cost-effective resource estimate of annual and peak savings
- For localized efforts, it helps inform a go/no-go decision

***Is the locational potential enough to meet utility targets?***

# Avista TLM: Forecast Using NWN Pilot Results


<i>Area</i>	<b>Utility Target Goal</b>	<b>Pilot Total Resource Results</b>	<b>Pilot Historical Results</b>
<b>Medford</b>	691	66	63
<b>Sutherlin</b>	121	18	12

*peak hour therms  
assumes three-year TLM project  
29 years needed to achieve targets at NWN pilot rate*

- NWN Pilot achieved 4% of resource potential in two years of enhanced incentives.
  - Generalizing to a three-year project this equates to roughly 12% of Avista's targets.
- NWN Pilot nearly doubled historical acquisition.
  - This would result in about 9% of Avista's targets in a three-year period.



# Past TLM Example: Gas efficiency measure mix



# Past TLM examples: Marketing materials

## TLM – Residential bill insert

### INCREASED INCENTIVES FOR HOME UPGRADES


**UPGRADE YOUR HOME FOR LESS**

Energy Trust of Oregon and NW Natural are working together to offer increased incentives and savings on energy-efficient upgrades for homes in your area.

From gas furnaces, to insulation, to smart thermostats and more, we've got you covered.





### MORE COMFORT, MORE SAVINGS

As a NW Natural customer, enjoy these limited-time exclusive incentives from Energy Trust:

- High-efficiency natural gas furnaces—**\$1,000**
- High-efficiency natural gas fireplaces—up to **\$250**
- Insulation—up to **\$1.25 per sq. ft.**
- Windows—up to **\$8 per sq. ft.**

For even more savings, we're also offering **\$100 off** qualifying smart thermostats, which let you control your comfort from anywhere.

**+** Visit [www.energytrust.org/nwnaturalpromo](http://www.energytrust.org/nwnaturalpromo) to get started.

Incentives are subject to funding availability and may change. Some qualifications apply.

## TLM – Commercial Postcard



### MAKE EVERY DOLLAR COUNT WITH LIMITED-TIME BONUS INCENTIVES



#### HELP YOUR BUSINESS SAVE

Energy Trust of Oregon offers cash incentives for upgrading to energy-efficient equipment that helps you lower operating costs, saving you money month after month. Plus, upgrades can help you create a more comfortable environment for your business year-round.

For a limited time, NW Natural customers can take advantage of bonuses on selected incentives. Bonus incentives are available now through December 3, 2020.

Complete an eligible upgrade and receive bonus incentives for:

- Lighting and landscape equipment
- Insulation
- Geosync equipment
- HVAC and water heating

**+** **READY TO SAVE? WE HAVE SOLUTIONS.**

To learn more about cash incentives, go to [www.energytrust.org/NWHSavings](http://www.energytrust.org/NWHSavings), email [existingbuildings@energytrust.org](mailto:existingbuildings@energytrust.org) or call 1.866.605.1676



421 SW Oak St., Suite 300  
Portland, OR 97204




Serving customers of NW Natural

Model with regular inserts on paper that contains post-consumer waste. ENR-0219

Phase/ Aspect	Identify constrained areas and utility needs	Analyze resource potential (one or many sites)	Develop program planning and strategies to meet localized needs	Go/No-Go decision with Energy Trust and utility partner	Build out budget and strategies for annual ETO budget	TLM Implementation
Energy Trust	Collaborates with utility partner to understand various utility needs (e.g., peak demand, flexible load, carbon)	Use Resource Assessment (RA) Model to estimate potential in local areas	Use existing suite of measures/offers mapped to each TLM area need; Consider local community needs for design and delivery	<b>Joint decision needed for Energy Trust's budget cycle</b>	Owns the program delivery strategy and implementation plan	Lead all aspects of implementation for EE and distributed RE (for electric)
Utility Partner	Analyzes grid needs and grid constraints, typically through IRP (historical) and new processes like DSP or CEP	Provides data on specific feeder(s) and any market verticals; Provides localized avoided costs estimates	Collaborate on Distributed Energy Resources (DERs) beyond EE, including DR/flex load, storage, EVs		Agrees to overall play through 1) overall budget process; 2) any additional funding	Collaborate in key areas – regional account management/outreach, CBAIGs, marketing
Community	<i>Potential to further automate early analysis with feeder data and RA model;</i> <b>Establish project leads with decision-making authority at each utility</b>	<i>Consider ETO Neighborhood Reports and/or Market Characterization Reports at this stage</i>	<i>To network with community partners early and often</i>	<i>Consider how both Energy Trust and utilities represent insights from community engagements</i>	<i>Demonstrate input via existing channels: Advisory Councils, outreach/community networks</i>	<i>Share insights of “how this is impacting communities”</i>

# Additional Program Delivery Strategies

- Fixed Price Promotions
- Community Partner Funding (CPF) promotions
- Community Based Organization (CBO) engagement
- Income qualified offers
- No-cost offerings (incentive covers full cost of measure)
- Direct Install offerings: Energy Trust coordinates install and pays full cost of measure
- Introduction of new measures such as: duct sealing and duct insulation





# Weather

Avista 2025 IRP

TAC 5 – June 5<sup>th</sup>, 2024

Tom Pardee

# Weather Forecasts

## Data by Planning Region


- Klamath Falls
- La Grande
- Medford
- Roseburg
- Spokane

## MACA 4.5 data<sup>1</sup>


- Multivariate Adaptive Constructed Analogs (MACA)
- Median HDD values of available studies by planning region
  - HDD calculated from Average of Min/Max by study
- Trended HDDs from 2026 – 2045
- Rolling 20-year blend (historic and MACA HDDs)

# MACA versus Actual Weather (Spokane)


## Weather Comparison



## 2020 – 2023 Comparison




# Weather History Comparison






# Klamath Falls Weather History and 4.5 MACA




## Weather History

20 Year rolling HDD daily average of 7,695 HDDs (2004-2023)



## 4.5 MACA


Trended reduction in HDDs from 2026 to 2045



## Peak HDDs


Coldest on Record Dates:  
12/21/1990  
12/8/2013  
1/6/2017

# La Grande Weather History and 4.5 MACA




## Weather History

20 Year rolling HDD daily average of 6,978 HDDs (2004-2023)



## 4.5 MACA


Trended reduction in HDDs from 2026 to 2045



## Peak HDDs


Coldest on Record Dates:  
1/31/1996

# Medford Weather History and 4.5 MACA




## Weather History

20 Year rolling HDD daily average of 4,965 HDDs (2004-2023)



## 4.5 MACA


Trended reduction in HDDs from 2026 to 2045



## Peak HDDs


Coldest on Record Dates:  
12/9/1972

# Roseburg Weather History and 4.5 MACA




## Weather History

20 Year rolling HDD daily average of 4,627 HDDs (2004-2023)



## 4.5 MACA


Trended reduction in HDDs from 2026 to 2045



## Peak HDDs


Coldest on Record Dates:  
12/22/1990

# Spokane Weather History and 4.5 MACA




## Weather History

20 Year rolling HDD daily average of 6,946 HDDs (2004-2023)



## 4.5 MACA

Trended reduction in HDDs from 2026 to 2045



## Peak HDDs

Coldest on Record Dates:  
12/30/1968

# Peak Day Options

## 99% Probability

---

Weather futures are higher than coldest on record and drastically increases the peak day for each area

Max daily temp across all weather futures

## Coldest on Record (COR)

---


Some coldest on record temps have not occurred in recent history

## COR less decrease in HDDs

---


Uses a coldest on record less the average decrease in temps from 2026 - 2045

# Klamath Falls



## 4.5 MACA

- 4.5 Median of future weather studies
- 20 year rolling average (historic + forecast)




## Peak

Coldest on Record less average forecasted annual decrease (2026-2045)

2025 IRP: 71 HDD peak planning

(89% probability in MACA 4.5)




## Historic Weather Comparison

1951 – 1981 Winters (Dec, Jan, Feb)

Compared to:


2001 – 2023 Winters (Dec, Jan, Feb)

# La Grande



## 4.5 MACA

- 4.5 Median of future weather studies
- 20 year rolling average (historic + forecast)




## Peak

Coldest on Record less average forecasted annual decrease (2026-2045)

2025 IRP: 73 HDD peak planning

(69.5% probability in MACA 4.5)



## Historic Weather Comparison


1951 – 1981 Winters (Dec, Jan, Feb)

Compared to:

2001 – 2023 Winters (Dec, Jan, Feb)




# Medford




## 4.5 MACA

- 4.5 Median of future weather studies
- 20 year rolling average (historic + forecast)



## Peak


Coldest on Record less average forecasted annual decrease (2026-2045)  
 2025 IRP: 60 HDD peak planning  
 (96% probability in MACA 4.5)



## Historic Weather Comparison


1951 – 1981 Winters (Dec, Jan, Feb)  
 Compared to:  
 2001 – 2023 Winters (Dec, Jan, Feb)

# Roseburg



## 4.5 MACA

- 4.5 Median of future weather studies
- 20 year rolling average (historic + forecast)




## Peak

Coldest on Record less average forecasted annual decrease (2026-2045)

2025 IRP: 53 HDD peak planning

(75.5% probability in 4.5 MACA)




## Historic Weather Comparison

1951 – 1981 Winters (Dec, Jan, Feb)

Compared to:


2001 – 2023 Winters (Dec, Jan, Feb)

# Spokane



## 4.5 MACA

- 4.5 Median of future weather studies
- 20 year rolling average (historic + forecast)




## Peak

Coldest on Record less average forecasted annual decrease (2026-2045)

2025 IRP: 79 HDD peak planning

(80% probability in MACA 4.5)



## Historic Weather Comparison

1951 – 1981 Winters (Dec, Jan, Feb)

Compared to:

2001 – 2023 Winters (Dec, Jan, Feb)

# Summary

- MACA 4.5 weather median futures trended from 2026 – 2045 by planning area and combine with historical actual data into a rolling 20-year average
- Peak Planning: coldest on record less average decrease in HDDs from 2026 - 2045